



FFPH.SA5723 Earthquake-actuated Shutoff Systems

[Page Bottom](#)

Earthquake-actuated Shutoff Systems

[See General Information for Earthquake-actuated Shutoff Systems](#)

PACIFIC SEISMIC PRODUCTS INC

SA5723

233 E AVENUE H8
LANCASTER, CA 93535 USA

Earthquake gas shut-off valves, Models 300, 301, 302, 303, 310, 311, 312, 313, 314, 314F, 315, 315F, 316, 316F, 317F, 318, 318F, 319F may be prefixed by "VT-" or "VB-".

Seismic actuated electrical switch assembly, Model 510.

These valves are special devices and are not regarded as substitutes for emergency gas shut-off valves covered by the National Fire Protection regulations. Local authorities having jurisdiction should be consulted before making installations. Valves must be installed in accordance with the manufacturer's instructions. In event of closure for any reason, precaution should be taken to check system beyond valve for leaks, open burners, pilots, etc., before resetting. **Suitable for use only with natural gas or LP-gas.**

[Last Updated](#) on 2004-09-08

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

◆ 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 150201-SA12452

ISSUE DATE: February 15, 2001

Page 1 of 1

Issued to: Pacific Seismic Products, Inc.

Report Reference: SA12452-150201

This is to Certify that
representative samples of: Earthquake Actuated Shutoff Valves,
Model Nos. 300, 301, 302, 303, 310, 311, 312, 313, 314, 314F, 315, 315F, 316,
316F, 317F

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.

Standard(s) for Safety: American Society of Civil Engineers, "Earthquake-Actuated Automatic Gas
Shutoff Devices", ASCE 25-97

Additional Information: N/A

Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control
number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate
UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:

Joe Carpenter
Underwriters Laboratories Inc.

Review Engineer:

Susan Stene
Underwriters Laboratories Inc.

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 080102-SA5723

ISSUE DATE:

August 1, 2002

Page 1 of 2

Issued to:

Pacific Seismic Products Inc
233 E Avenue H8
Lancaster, CA 93535

Report Reference:

SA5723, May 1, 1997

**This is to Certify that
representative samples of:**

Earthquake Actuated Automatic Gas Shutoff Valves, Models 300, 301,
302, 303, 310, 311, 312, 313, 314, 314F, 315, 315F, 316, 316F, and 317F.

**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.**

Standard(s) for Safety:

Earthquake Actuated Automatic Gas Shutoff Devices, ASCE 25-97. Also
Complies with Earthquake Actuated Automatic Gas Shutoff Systems, ANSI
Z21.70.

Additional Information:


Refer to the attached Addendum Page for Sizes and Ratings on the above
Models.

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.**


The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number
(may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:


Robert Warren
Underwriters Laboratories Inc.

Review Engineer:


Greg Okada
Underwriters Laboratories Inc.



Northbrook, Illinois • (847) 272-8600
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 080102-SA5723

Page 2 of 2


ISSUE DATE: August 1, 2002

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Earthquake Actuated Automatic Gas Shutoff Valves, Models 300, 301, 302, 303, 310, 311, 312, 313, 314, 314F, 315, 315F, 316, 316F, and 317F, may be prefixed by "VT-" or "VB-".


Model No.	Flange Size (in.)	NPT Pipe Size (in.)	Maximum Operating Pressure (PSIG)
300	--	3/4	0.5
301	--	1	0.5
302	--	1 1/4	7.0
303	--	1 1/2	7.0
310	--	3/4	60
311	--	1	60
312	--	1 1/4	60
313	--	1 1/2	60
314	--	2	60
314F	2	--	60
315	--	3	60
315F	3	--	60
316	--	4	60
316F	4	--	60
317F	6	--	60

Engineer:


Robert Warren

Underwriters Laboratories Inc.

Review Engineer:


Greg Okada

Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service